

Formaldehyde Emission Test Certificate

Wednesday, October 3rd 2018



Supplier: OZ Wood (Australia) Pty Ltd (D2/290 Parramatta Road, Auburn, NSW, 2144).

Sample Description: Barock Laminate Floor - 12mm HDF Laminated Floorboard.

Date Tested: 02nd October 2018 (Tested by NATA Accreditation No: 15305 Laboratory).

Test Method: AS/NZS 4266.1:2017 section 17 "Standard Method for Formaldehyde Emission Testing – Desiccator Method".

Emission Data:

Green Building Council of Australia Green Star Office Design & As Built v1.1	Barock Laminate Floor - 12mm HDF Laminated Floorboard
Formaldehyde emission limit (Particleboard): E0 ≤0.5 mg/L	Formaldehyde emission rate: 0.33 mg/L
Formaldehyde Emission Class as per AS/NZS 1859.2:2017: E0 (Pass)	
	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV180965